



- NOTES:
1. TOP 1' OF PAD TO BE 24" X 24" SQUARE
  2. BOTTOM 24" OF PAD TO BE 24" CYLINDER FORMED WITH SONA TUBE
  3. A SECOND GROUNDING ROD IS TO BE LOCATED 6' AWAY FROM THE BASE WITH A #6 GROUNDING CONDUCTOR RUNNING TO IT WITHIN A  $\frac{3}{4}$ " CONDUIT



STANDARD DETAILS  
LIGHTING EQUIPMENT PAD

COTTAGE GROVE, MINNESOTA

JANUARY 2021

PLATE NO.  
LGT-6